



**CERTIFICATE** No. 00003/101/1/2021  
on January 12<sup>th</sup>, 2021

Certification body of EVPÚ a.s. confirms the compliance of the product with requirements of undermentioned standards.

**Product:** Analogue addressable optical smoke and rate-of-rise heat detector with integrated isolator

**Type:** BSR-6157

**Specification:** 12 - 30 VDC

**Client/Manufacturer:** Olympia Electronics N. Lakasas - P. Arvanitidis S.A.  
72nd klm old national road Thessaloniki - Katerini, 60300 Eginio, Greece

**Manufacturing facilities:** Olympia Electronics N. Lakasas - P. Arvanitidis S.A.  
72nd klm old national road Thessaloniki - Katerini, 60300 Eginio, Greece

**Standards:** EN 55032: 2015 + A11: 2020  
EN 50130-4: 2011 + A1: 2014

Results of tests of mentioned product are summarized in Final report on assessment No. 0-0004/21/C of January 12<sup>th</sup>, 2021.

Used standards are harmonized with directive of the European parliament and of the Council 2014/30/EU transposed into Slovak government decree No. 127/2016 Z. z.

Validity of certificate  
is limited for the period  
from: January 12<sup>th</sup>, 2021  
until: January 11<sup>th</sup>, 2024



Marek H u d á k

Any significant changes in the design or construction of the products or amendments of the technical decrees reference above may render this Certificate invalid. The product liability rests with the manufacturer or his representative.

EVPÚ a.s., Trenčianska 19, 018 51 Nová Dubnica, Slovak republic, [www.evpu.sk](http://www.evpu.sk)

053883