## **DECLARATION OF PERFORMANCE**



No. 921163200\_59\_004

- 7. Unique identification code of the product-type: BS-1632
- 8. Intended use/es: 2 zones conventional fire alarm control panel for use in fire detection and fire alarm systems installed in buildings.
- 9. Manufacturer: Olympia Electronics N. Lakasas P. Arvanitidis S.A. 72<sup>nd</sup> klm Old national road Thessaloniki Katerini, Kolindros, Pieria, Greece P.O. 60061
- 10. System/s of AVCP: System 1
- 11. Harmonized standard: EN 54-2:1997 +A1:2006 Fire detection and fire alarm systems Part 2: Control and indicating equipment

EN 54-4: 1997 +A1:2002 +A2:2006 Fire detection and fire alarm systems – Part 4: Power supply equipment

Notified body/ies: HELLENIC ELECTRONIC EQUIPMENT QUALITY ASSURANCE CENTER, No. 0848

		Harmonised technical specification:		
			EN 54-4:1997	
Essential characteristics	Performance	EN 54-2:1997	+A1:2002	
		+A1:2006	+A2:2006	Comments
	PASS	4ª, 5ª, 6ª, 7ª, 8ª, 9ª,		
Operational reliability		12 <sup>a</sup> , 13 <sup>a</sup> , 14 <sup>a</sup>	4 <sup>b</sup> , 5 <sup>b</sup> , 6 <sup>b</sup> , 7 <sup>b</sup> , 8 <sup>b</sup>	a, b
Durability of operational				
reliability: Temperature	PASS			
resistance		15.4	9.5	
Durability of operational				
reliability: Vibration	PASS			
resistance		15.6, 15.7, 15.15	9.7, 9.8, 9.15	
Durability of operational				
reliability: Humidity	PASS			
resistance		15.5, 15.14	9.6, 9.14	
Durability of operational	PASS			
reliability: Electrical				
stability		15.8 to 15.13	9.9 to 9.13	
Response delay	PASS			
(response time to fire)		7.1, 7.7, 7.11, 7.12		а
Performance under fire	PASS			
conditions		4, 5, 7		a, b
Performance of power	PASS			
supply			4, 5, 6	b

Headquarters: 72 km Old Highway Thessaloniki Katerini, Postal code 60 300, P.O.Box 06, Eginio - Pieria – Greece T. +30 23530 51200 | F. +30 23530 51486 | info@olympia-electronics.gr

> Athens Branch: 18 Leontariou street, Kantza, Postal code 15351 Palini, Greece T. +30 210 985 2193-4 | F. +30 210 985 2225 | athens@olympia-electronics.gr

> > www.olympia-electronics.gr

Comments:

a) The product has been certified with the available options with requirements of the harmonized technical specification **EN** 54-2:1997 +**A**1:2006 which are mentioned below.

7.8 Output to fire alarm devices

7.11 Delays to outputs

b) The product covered by the standards that are mentioned above is assumed to function during the alarm condition, in an event of fire, before the fire becomes as large as to affect its functioning. There is therefore no requirement to function when exposed to direct attack from fire.

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:



Elias Tsologiannis, R&D engineer

Eginio, Pieria, Greece 25/1/2018

Athens Branch: 18 Leontariou street, Kantza, Postal code 15351 Palini, Greece T. +30 210 985 2193-4 | F. +30 210 985 2225 | athens@olympia-electronics.gr