

Certificate of constancy of performance,

0832-CPR-F0139

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

GS506 Battery Operated Photoelectric Smoke Alarm (Replaceable Battery) For Use In Fire Detection And Alarm Systems

(For full product details and conditions of use refer to appendix)

Produced by or for

Ningbo Siterwell Electronics Co., Ltd

**No.76 Haichuan Road, Chuangye Zone B
Jiangbei
Ningbo
315032
China**

and produced in the manufacturing plant(s)

Ningbo Siterwell Electronics Co., Ltd

**No.76 Haichuan Road, Chuangye Zone B
Jiangbei
Ningbo
315032
China**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 14604:2005/AC: 2008 - Smoke alarm devices

Under system 1 are applied and that

The product fulfils all the prescribed requirements set out above.

This certificate was first issued on 19 June 2014 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



S. Patrick, Business Group Manager
On behalf of BRE Global Limited
Date of issue: 19 June 2014
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.

Appendix to Certificate of constancy of performance 0832-CPR- F0139

Variants:

GS506A (Silver Coloured Cover)

GS506H (Wood Coloured Cover)

Note:

1. Battery types approved with this domestic smoke alarm

- Raymax: 6LR61
- Duracell: 6LR61 or MN1604
- Golite: G6F22 or 1604D
- Forte: ER9V
- Gold Peak: GP1604S or GP1604A or 6LF22 or 6LR61 or MN1604
- Golden Power: G6F22A or G6F22M or S006P or 1604D or 6F22
- Lonlife: 6F22



S. Patrick, Business Group Manager
On behalf of BRE Global Limited
Date of issue: 19 June 2014
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.